

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

9/6/25

It is certified that an inspection team headed by Dr. Sunil Patel

From PHC Vadodara PHED inspected the Bright International School, Karaigam Road, S.P.Ring Road, Valad, Gandhinagar. on 9/6/25 and on the basis of Water Test Report (Attached) bearing no 367/2025-26 dated 29.05.2025 of DISTRICT LABORATORY GANDHINAGAR (PHED Lab) certified that the Bright International School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the State Govt.

This certificate is valid till

Signature with Seal: [Signature]

Name Dr. Sunil Patel

Designation : Medical Officer

Name & Address of the Office / Department : PHC Vadodara
Ta Dist Gandhinagar



To

Bright International School
Karaigam Road, S. P. Ring Road,
Valad, Gandhinagar

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

[Signature]
Principal
BRIGHT INTERNATIONAL SCHOOL
Post Valad, Dist. Gandhinagar-382 355.

[Signature]
Managing Trustee
BRIGHT INTERNATIONAL SCHOOL
(English Medium)
Post Valad, Dist. Gandhinagar-382355.



DISTRICT LABORATORY
GUJARAT JALSEVA TRAINING INSTITUTE
GUJARAT WATER SUPPLY & SEWERAGE BOARD
SECTOR - 15, 'G' Road, GANDHINAGAR - 382016



REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER

Name & Address:-

Bright International School	Sender's Ref.No:	-
Karai	Date of Receipt at Lab. / Arrival Date:	26-May-25
Gandhinagar	Sample Collected By:	Sender

Lab Ref. i.e. BW No.	325
Date of Collection	26-May-25
Date of Commencing Examination:	26-May-25
Source of Water Sample	Bore Water
	Bright International school
Village	Karai
Habitation	Karai
Taluka	Gandhinagar
District	Gandhinagar
Membrane Filtration Method, IS-15185:2016, ISO 9308-1:2014 for Total Coliform	< 1
Membrane Filtration Method, IS-15185:2016, ISO 9308-1:2014 for Therotolerant Fecal Coliform (<i>E.coli</i>)	< 1
Opinion For Potability As Per The BIS:10500:2012	Safe

Important Note:-

- *Sample should be collected in sterile BOD bottle.
- *"Unsafe" :- Proper Disinfection may render it safe.
- *Presence of Coliform in water sample indicates the need of proper Disinfection.

NOTE :

Table - 6 Bacteriological Quality of Drinking Water (BIS:10500:2012) : Second Revision.

*All Water Intended for Drinking -

(a) *E.coli* or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.

*Treated Water Entering the Distribution system & Treated Water in the Distribution system -

(a) *E.coli* or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.


(b) Total coliform bacteria shall not be detectable in any 100ml sample.

1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.

2) This Report should not be taken as a basis to getting license from any Government authority.


3) After Collection of Bacteriological sample, it must be preserved at (5±3)°C and submitted to laboratory within 24hrs.

Analysed By : 
Microbiologist


Lab Incharge

Outward No.: GJTI/Dist.Lab/BWT 325 / of 2025, Date: 5 / 6 / 2025


Principal
BRIGHT INTERNATIONAL SCHOOL
Post Valad, Dist. Gandhinagar-382 355.


Managing Trustee
BRIGHT INTERNATIONAL SCHOOL
(English Medium)
Post Valad, Dist. Gandhinagar-382355.



GUJARAT WATER SUPPLY & SEWERAGE BOARD
DISTRICT LABORATORY GANDHINAGAR
 Ground Floor, GJTI, G-Road, Sec-15, Gandhinagar



Test Report

Name & Address of Customer:-

Bright International School

Karai

Gandhinagar

Customer Reference No.:-

Sample Submitted by :Customer

Date of Sample Receipt :26-May-2025

Analysis Starting Date :28-May-2025

Analysis Completion Date :28-May-2025

Dicipline:Chemical Testing,Group:Drinking Water

ULR - TC129242500000367F

Test Report No.: 367/2025-26

Date of Issue : 29-May-2025

Sample ID : 367

Mode of Sample: Satisfactory

Main Source :Ground Water

Source :Bore Water

Location :Bright International school

Village :Karai

Habitation :Karai

Taluka :Gandhinagar

District :Gandhinagar

Latitude :-

Longitude :-

Kindly find herewith the Analytical Results.

Sample Type : Drinking Water

Sr.No.	Parameter	Unit	Reference Method :	Analytical Value
1	Odour	-	IS : 3025 (Part 5) - 2018	Agreeable
2	Turbidity	NTU	APHA (24 th Ed.2023), Method: 2130 B	1.02
3	pH at 25°C	-	APHA (24 th Ed.2023) Method: 4500 H ⁺ B	7.08
4	Conductivity at 25°C	μS/cm	APHA (24 th Ed.2023) Method: 2510 B	227
5	Total Dissolved Solids	mg/l	APHA (24 th Ed.2023) Method: 2540 C	184
6	Total Hardness(as CaCO ₃)	mg/l	APHA (24 th Ed.2023) Method: 2340 C	124
7	Calcium (as Ca ⁺²)	mg/l	APHA (24 th Ed.2023) Method: 3500 Ca+2 B	32
8	Magnesium (as Mg ⁺²)	mg/l	APHA (24 th Ed.2023) Method: 3500-Mg+2 B	11
9	Chloride (as Cl ⁻)	mg/l	APHA (24 th Ed.2023) Method: 4500-Cl – B	32
10	Sulphate (as SO ₄ ⁻²)	mg/l	APHA (24 th Ed.2023) Method: 4500-SO4-2 E	11
11	Nitrate (as NO ₃ ⁻)	mg/l	APHA (24 th Ed.2023) Method: 4500-NO3- B	41.68
12	Fluoride (as F ⁻)	mg/l	APHA (24 th Ed.2023) Method: 4500-F – C	0.13
13	Total Alkalinity(as CaCO ₃)	mg/l	APHA (24 th Ed.2023) Method: 2320 B	140

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.

Issued By:

Khyati Nayak

Khyati Nayak
(Quality Manager)
Authorized Signatory



----- End of the Test Report -----

O.W.No. DL/GNR/ 367 /of 2025, Dt. 29/5 / 2025.

Ground Floor, GJTI, G-Road, Sec-15, Gandhinagar

E-mail: districtlabgandhinagar@gmail.com

[Signature]
Principal
BRIGHT INTERNATIONAL SCHOOL
Post Valad, Dist. Gandhinagar-382 355.

K.V. Trivedi
Managing Trustee
BRIGHT INTERNATIONAL SCHOOL
(English Medium)
Post Valad, Dist. Gandhinagar-382355.